



**NOTE :**

DURING SUBGRADE CONSTRUCTION, A MINIMUM OF 0.3 m OF COVER IS TO BE PROVIDED AND MAINTAINED OVER THE REINFORCED CONCRETE PIPE CULVERT TO PROTECT THE STRUCTURE FROM DAMAGE.

	DWG. No	CB - 6 2.4.M5
		Date
	Original	April, 1979
	Revised	

**TYPICAL CROSS-SECTION  
OF  
REINFORCED CONCRETE  
PIPE CULVERT INSTALLATION  
FOR MEDIAN DRAINAGE**